



Project Information

2018 IECC
231032 Panda Express (Concord, NC)
New Construction

Owner/Agent:
Panda Express Chinese Kitchen
Rosemead, California 91770

Additional Efficiency Package(s)

Credits: 1.0 Required 1.0 Proposed

Allowed Interior Lighting Power

Total Allowed Watts = 2054

Proposed Interior Lighting Power

Total Proposed Watts = 1

Interior Lighting PASSES: Design 11% better than code

Compliance Statement: The proposed interior lighting design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed interior lighting systems have been designed to meet the 2018 IECC requirements in COMcheck Version COMcheckWeb and to comply with any applicable mandatory requirements listed in the Inspection Checklist.

Report date: 06/01/23
Page 1



Project Information

2018 IECC
231032 Panda Express (Concord, NC)
New Construction
4 (High activity metropolitan commercial district (LZ4))

Owner/Agent:
Panda Express Chinese Kitchen
Rosemead, California 91770

Allowed Exterior Lighting Power

Total Tradable Watts (a) =
Total Allowed Watts =
d Supplemental Watts (b) =

(a) Wattage tradeoffs are only allowed between tradable areas/surfaces.
(b) A supplemental allowance equal to 900 watts may be applied toward compliance of both non-tradable and tradable areas/surfaces.


Proposed Exterior Lighting Power

Total Tradable Proposed Watts =

Exterior Lighting PASSES: Design 57% better than code

Compliance Statement: The proposed exterior lighting design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed exterior lighting systems have been designed to meet the 2018 IECC requirements in COMcheck Version COMcheckWeb and to comply with any applicable mandatory requirements listed in the Inspection Checklist.


Report date: 06/01/23
Page 1



CANOPY LIGHTING PLAN	1
----------------------	---

Scale: 1/4"=1'-0" E-101

- KPI ENGINEERING, INC.**
- PROFESSIONAL ENGINEER
- "No matter the Scope, KPI has YOU Covered"*
- 3203 QUEEN PALM DRIVE
TAMPA, FLORIDA 33619
PHONE (813) 241-6488
FAX (813) 241-6498
- BOARD OF PROFESSIONAL ENGINEERS - LICENSE # C-4604



Telephone: 626.799.9898
Facsimile: 626.372.8288

All ideas, designs, arrangement and plans indicated or represented by this drawing are the property of Panda Express Inc. and were created for use on this specific project. None of these ideas, designs, arrangements or plans may be used by or disclosed to any person, firm, or corporation without the written permission of Panda Express Inc.

REVISIONS:


ISSUE DATE:

DRAWN BY: BDG

PANDA PROJECT #: D24958

PANDA STORE #: TBD

ARCH PROJECT #: 23920



LUIS G. VARGAS JR, P.E.
NC LIC. # 028003

PANDA HOME 2600
450 Kannapolis Parkway
Concord, NC 28027

E-101.1

PANDA HOME 2600 R3